		R13	SCR POWER HOUSE with Drillers Control Interface
1	1	Set	SCR POWER HOUSE CENTER COMPLETE c/w GENSET CONTROL, SCR DRIVE, MCC & POWER HOUSE AND DRILLERS CONSOLE INTERFACE (HMI, TORQUE, LIMIT, PHEOSTAT) SCR MUST BE COMPATIBLE WITH CATERPILLAR 3512B generators.
Α	4	Pcs	AC SWITCH BOARD(600VAC ALTERNATOR GENSET CONTROL AND DISTRIBUTION) - ROSSHILL
			- Four(4) generator control switchboards to control engine/generator sets 1421KVA/995KW,600V,3phase, 60HZ, 0.7 PF, 1200RPM, excitation voltage SSV, excitation current 6.7 Amps
			Each Generator control will contain the following components:
			Main Circuit Breaker;
			Metering: Ammeter, Kilovar meter, Kilowatt meter, Voltmeter meter;
			Protective Circuits: UnderVoltage, Over Voltage, Over Frequency, Under Frequency, Reverse Power, Circuit Breaker Open, Circuit Breaker Closed, Power Limiting, Generator Run light;
			Generator Voltage Regulator control:
			Engine Governor Control: Solid State Governor Control, Automatic KW load sharing.
	1	Set	Synchronized detection and merging system
	<u> </u>	361	Synchronized detection and merging system
			Synchronizing System
	1	Set	Grounding detection system
			Ground Detection Lights, Percent AC ground meter, Grounding Resistors, one(1) per phase, Ground Circuit Test Button - "Push to Test"
	1	Set	24V DC power supply unit for engine
	1	Set	Power limit system
			EMI Filtering Notes:
			All Wiring associated with electronic equipment shall be kept separate from power wiring.

		1	
			All control wiring will utilize ferrules for terminations to insure a positive connections
			All control power circuits and P.T. circuit wiring shall be protected by fuses.
			Terminal blocks shall be rated to withstand the maximum continous current rating and voltage rating of the connected circuits.
			Fuse holders for control P.T. circuits will be of a design defined as "finger safe" minimizing The exposure to the personnel to arcing caused by making or breaking a circuit under load. and all materials, equipment, workmanship will be in compliance to the latest editions of ANSI C-37 for metal enclosed distribution switchgear, IEEE-45, NFPA, UL and API as appropriate.
			The 600 VAC Generator Control shall be freestanding metal enclosed switchgear built in conformance with ANSI C-37 requirements.
			The Equipment shall be front access only
			The construction of the system shall be of a type suitable for use in an oilfield environment.
			The equipment shall be self-ventilating.
			The equipment Is designed to fully control and protect a diesel electric genratorset rated 600VAC, 3 phase, three wire, 60Hz.
В	5	Pcs	SCR DRIVES (ROSSHILL) with EMI signal filtering, Sprocket Sllp/HED and Drawworks Dynamic Brake system (RESISTANCE CAPACITANCE ABSORPTION CIRCUIT)
			Six (6) SCR Drives cubicle Contains the following DC series Traction motor to be controlled. Motor Loads(Reversing)
	1	ea	-Drawworks A, High torque series type motor, YZ08,800KW, 1150Amps, 970RPM, 750VDC-1ea
	1	ea	-Drawworks B, High torque series type motor, YZ08,800KW, 1150Amps, 970RPM, 750VDC-1ea
	1	ea	Rotary Table, High torque series type motor, YZ08,800KW, 1150Amps, 970RPM, 750VDC-1ea Motor Loads(Non-reversing)
	2	ea	MP1, High torque series type motor, YZ08,800KW, 1150Amps, 970RPM, 750VDC-2ea

			MCC is front access, self-ventilating design and rated 480V three phase, 3wire, 60Hz.
D	1	Set	480V MCC (GCS)
			- Communication Loss Indicator
			- System Alarm Indicator
			- MP3 Lockout Switch 3#
			- MP2 Lockout Switch 2#
			- MP1 Lockout Switch 1#
			- RT Lockout Switch
			- DW Lockout Switch
			- Touch Select Features
			- Trobubleshooting Diagnostics
			- Detail Status Overview
			High Resolution HMI Touchscreen to include:
			PURPOSES.
			S71500 WITH EMI SIGNAL FILTERING AND DOOR MOUNTED HIGH RESOLUTION HMI TOUCHSCREEN FOR TROUBLESHOOTING
С	1	Set	All PLC System
	1	ea	Foot Throttle
			Draw works Dynamic brake systeym
		ea	
	3	ea	Sprocket slip
	2	ea	-MP3, High torque series type motor, YZ08,800KW, 1150Amps, 970RPM, 750VDC-2ea
	2	ea	750VDC-2ea
			MP2, High torque series type motor, YZ08,800KW, 1150Amps, 970RPM,

	ı	
		The motor control center is rated and braced for 42KAIC at 480VAC. Each motor starter and circuit breaker is fully rated. All motor starter circuit breakers are magnetic only type, and sized for horsepower indicated. All feeder breakers are thermal magnetic. Each motor control center is plug removable, and is supplied with single primary fused control power transformer for remote 120VAC control. Each motor starter is supplied with a Hand-Off-Auto controller, or provisions for a three-wire remote push-button stop/start station as required. Each motor circuit is supplied with wired to a matching power(4pins) and control receptacle(4pins) on the Power control house. Each distribution feeder breaker is wired to matching terminal block.
		Note: The control center is unable to list UL and label it. A Certificate of Conformity can be issued.
		Motor Control Circuits Designations: Feeders transformers 600VAC to 480VAC
		*Aground fault monitoring system will be provided for the 480VAC Distribution System
		All Wiring associated with electronic equipment shall be kept separate from power wiring.
		All control wiring will utilize ferrules for terminations to Insure a positive connections
		All control power circuits and P.T. circuit wiring shall be protected by fuses.
		Termnal blocks shall be rated to withstand the maximum continous current rating and voltage rating of the connected circuits.
		Fuse holders for control P.T. circuits will be of a design defined as "finger safe" minimizing the exposure to the personnel to arcing caused by making or breaking a circuit under load. Motorloads,460VAC
		Motor Loads, 460VAC
		Softstart with bypass design in case the softstart fails - with HOA & indicating lights :
3	ea	75HP Supercharger
2	ea	75HP Mud Mixer
1	ea	75HP Desander

		T
1 6	ea	75HP Desilter 1EA -
	<u></u>	76TH Booker TEX
		75HP Demuding
1 (ea	75HP Cutting Pump
		FAN & COOLING CHEST - DOL with HOA & indicating lights : (MCC BUCKETS) All the MCC Buckets should be Draw Out Type with lock out tagout*
2	ea	15HP Fan Blower AC Motor Drawworks A&B
2	ea	5HP Disk Brake Cooling Pump
2	ea	15HP Fan Blower AC Motor Mud Pump
1 6	ea	3HP Liner Wash, MP1
1 6	ea	3HP Oil Cooling Pump, MP1
2	ea	15HP Fan Blower AC Motor Mud Pump
2	ea	3HP Liner Wash, MP2
1 (ea	3HP Oil Cooling Pump, MP2
2	ea	15HP Fan Blower AC Motor Mud Pump 3
1 (ea	3HP Liner Wash, MP3
1 (ea	3HP Oil Cooling Pump, MP3
		CIRCUIT BREAKER (MCC BUCKETS) with ON/OFF & indicating lights :All the MCC Buckets should be Draw Out Type with lock out tagout*
2 (ea	160Amps CB - 75HP Centrifuge Pump 2EA x 160Amps CB - 75HP Mud Cleaner 1EA x 100Amps CB - 60HP Degasser
2	ea	100Amps CB - 50HP Water Pump
1 6	ea	160Amps CB - 50HP Water Well Pump
2	ea	100Amps CB - 50HP Diesel Oil Pump
1 (ea	1160Amps CB - 75HP Spare

	4		100A OD
	1	ea	100Amps CB - 50HP Spare
	2	ea	160Amps CB - 30HP Air Compressors
		<u></u>	Tool lines of the first of the control of the contr
	1	ea	60Amps CB - 25HP Trip tank
	1	ea	160Amps CB, (3ea)20HP Mud Agitators (Premix Tank1)
	1	ea	160Amps CB, (3ea)20HP Mud Agitators (Premix Tank2)
	1	ea	60Amps CB, (3ea)20HP Mud Agitators (Reserve Tank1)
	1	Ca	ODAMPS OB, (Sea)2011 Widd Aghalors (Reserve Talikt)
	1	ea	160Amps CB, (3ea)20HP Mud Agitators (Reserve Tank 2)
	1	ea	160Amps CB, (3ea)20HP Mud Agitators (Suction Tank)
	1	ea	160Amps CB, (3ea)20HP Mud Agitators (Intermediate Tank)
	1		400Amana CD (2a a)200 ID March A sitatana (March Clause at Tamb)
	1	ea	160Amps CB, (3ea)20HP Mud Agitators (Mud Cleaner Tank)
			60Amps CB, (3ea) 20HP Agitators & 3EA - 7.5HP Shale Shakers (Shale
	1	ea	Shaker Tank)
	2	ea	2EA x 60Amps CB- 20HP Disk Brake Cooling Pumps
	_		
	2	ea	60Amps CB - 20HP Water Pumps
	1	ea	60Amps CB - 20HP Koomey Units (BOP)
	'	Са	OUATIPS CB - 2011 Rootiley Offics (BOT)
	1	ea	60Amps CB - 20HP Spare
	2	ea	60Amps CB- 5HP Fuel Pump
	1	ea	160Amps CB - 5HP Cellar Pump
			60Amna CR - EUD Steam Cleaner
		ea	60Amps CB - 5HP Steam Cleaner
	1	ea	60Amps CB- 5HP Vacuum Degasser
			1
	1	ea	60Amps CB- 5HP Spare
	1	ea	160Amps CB- Hydraulic Pressure Station
	1	ea	60Amps CB - Multi level
	1	ea	160Amps CB- Cooling POT
		Ja	Toorkings OD- Cooling I OT
1	$\vdash \vdash$		
	1	ea	200Amps CB- Hive POT

l			
	1	ea	160Amps CB - Boiler House
	<u> </u>	Ju	Took will be the control of the cont
			60Amps CB - Drill Power
	1	ea	OUATIPS OD - DITIL I OWO!
	<u> </u>	ea	60Amps CB - gas room
	<u> </u>	Ca	OUATIPS OD - gas Toolii
	1	ea	160Amps CB - well power
		-	
	1	ea	160Amps CB - Air condition unit
	1	ea	160Amps CB - Geologragh room
E			Air condition unit
F			Top drive supply power, 600 VAC,(IN=1250A)
			LICUTING DANIEL (A well provided lighting payable growth of fact
G.			LIGHTING PANEL:(A wall-mounted lighting panel is provided for the following circuits)
			lollowing circuits)
			Transformer Feeder Circuit Breaker
			Transferment research encouncer
			Branches: 27 branches
			Living Area,200A, 208Vac, 3phase, MCCB
			Generator #1 Lighting 63A,2P with GFCI , 30mA, 120Vac, miniature type
			Generator #2 Lighting 63A,2P with GFCI, 30mA, 120Vac, miniature type
			Company 40 Limbing COA OF with OFOL 20mg A 400 V/co maining to make
			Generator #3 Lighting 63A,2P with GFCI , 30mA, 120Vac, miniature type
			Generator #4 Lighting 63A,2P with GFO , 30mA, 120Vac, miniature type
			Soliciator #4 Eighting Con,21 with Or O , Solin, 120 vac, Illinature type
			Power Driller House, 63Amps, 3P, 120Vac, miniature type
			, ,
			Power Drill Rlg floor, 63Amps, 3P, 120Vac, miniature type
			Fixed Control Lighting I,63A, 2P, 120Vac, miniature type
			Fixed Control Lighting II, 63A,2P, 120Vac, miniature type
			F: 10 1 11:11: W 004 05 1001
			Fixed Control Lighting III, 63A, 2P, 120Vac, miniature type
			Fixed Central Lighting IV 62A 2D 420Vac ministrus time
			Fixed Control Lighting IV, 63A, 2P,120Vac, miniature type
			Fixed Control Lighting V, 63A, 2P, 120Vac, miniature type
		<u> </u>	prince Control Lighting v, Con, 21, 120 vac, fillinature type

	Fixed Control Lighting VI, 63A, 2P, 120Vac, miniature type
	Fixed Control Lighting VII, 63A, 2P, 120Vac, miniature type
	Fixed Control Lighting VIII, 63A, 2P, 120Vac, miniature type
	Multi Level Tank Lighting, 63A, 2P, 120Vac, miniature type
	Diesel Oil Tank Lighting, 63A, 2P, 120Vac, miniature type
	Diesel Oil Tank Lighting, 63A, 2P, 120Vac, miniature type
	Cooling Water Tank Lighting, 63A, 2P, 120Vac, miniature type
	Staff House Lighting, 63A, 2P, 120Vac, miniature type
	Right Dog House Lighting, 63A, 2P, 120Vac, miniature type
	Water Tank Lighting, 63A, 2P, 120Vac, miniature type
	SCR Room Lighting, 63A, 2P, 120Vac with GCFI, miniature type
	OOK ROOM Eighting, OOA, 21 , 120 vac with OOI i, miniature type
	Geolograph Room Lighting, 63A, 2P, 120Vac with GCFI, miniature type
	DC motor Heater 1 , 208Vac, miniature type DC motor Heater 2 , 208Vac, miniature type
Н	POWER AND CONTROL RECEPTACLES (Matching plugs for all power & control receptacles should be provided)
	- Power Receptacles Generators - Bus & Stabs
	All 3 phase AC Power - (4 plns)
	- Control Receptades
	Generators - (4pins)
	AC Control - (4pins)
I	ICABLES-CONTROL (FROM SCR TO DRILLERS CONSOLE) WITH PLUGS AND RECEPTACLE
J	CABLES-CONTROL (FROM SCR TO GENERATORS) WITH PLUGS AND RECEPTACLE K
K	PORTABLE DEHUMIDIFIER WITH DIGITAL METER

ī	POWER CONTROL HOUSE
	FOWER CONTROL HOUSE
	The building shall be <u>2.75 meters wide by 12,9 meters long by 2.9 meters high</u> . The building shall be of a modular, typical oilfield, with two runner skid mounted enclosed structure. The house will be an interlocking panel design. The house shall be insulated and provided with one 2-ton <i>NC</i> unit for ventilation or as per your designed.
	The base of the building shall be adequately sized structural steel members rigidly braced with structural steel cross members.
	Thers shall be one(2) access door provided and It shall be supplied with automatic door closure
	- There's should be removable stairs to climb in the roof
	-Floor finish to be high voltage Rubber matting In gray color and diamond shape with certificate mark.
	- House shall be provided with fluorescent fixtures, convenience outlets, and one (1) emergency lights
	Plug Panel will be through-the-wall design.Plug Panel to be angled for Plug-Ins.
	The standard lifting eyes should be provided to facilitate transportation and lifting for all the Panels and Building House.
	Power House Paint recommended Specifications:
	Structural:
	- Structural steel shall be deaned
	- 0.5 to Imil of inorganic zinc primer shall be applied
	- A final coat of 2-3mils of urethane shall be applied
	Interior Galvanized Surface
	- All surfaces shall be cleaned with lacquer thinner to remove any existing grease,oll and
	dust and all seams are sealed with urethane caulking
	- Self etching primer shall be applied to the surface. Final mil thickness will be 0.5 mil

 <u> </u>	T
	- Polyurethane shall then be applied as the finish coat with a 2-3 mil dry finish
	Exterior Galvanized Surfaces: (Trim Facia, Etc.)
	- All surfaces shall be cleaned with lacquer thinner to remove any existing grea
	oil, and dust and all seams are sealed with a urethane caulking
	- Self-etching primer shall be applied to the surface. Final mil thickness will be
	- An intermediate coat of 2-3mlls of high build epoxy shall be applied
	- Polyurethane shall then be applied as the finish coat with a 2-3 mils dry finish
1 Lot	DRILLERS CONTROL INTERFACE (HIGH RESOLUTION HMI, Rheostat, Torque Limit, Foot throttle)
	I PRIOR VISIT AT RIG LOCATION
1 Lot	-Prior Visit at Location - the rate of the technician and how long it takes to finish the initial inspection.
	Note: If your technicians are not allowed to travel Libya your proposals/quotation considered invalid.
1 LOT	TRAINING FOR ELECTRICIAN (4EA)
	-Training for four(4) Electrician - the location of the training and detailed cost should be reflected in the
	offer
1 LOT	FULL DOCUMENTATIONS (3SETS) Hard copies and 1 soft copy
	- Detailed and complete One Line & Schematic Diagram
	- Certificate of conformity
	- Initial Test Results
	Brochures and catalogue for all parts and devices used
	User and Part Manual
	INSTALLATION AND COMMISSIONING AT RIG LOCATION

1	IOT	-Installation and Commissioning at Rig Location - the rate of the technician and how long it takes to finish the project should be reflected in the offer. Note: If your technicians are not allowed to travel Libya your proposals/quotation considered Invalid.
		NOTES: REQUIRED TO SUBMIT DETAILED OFFER INCLUDING THE FOLLOWING (LAYOUT AND SCHEMATIC)
		SCR HOUSE EXTERNAL LAYOUT
		SCR HOUSE INTERNAL LAYOUT-GEN& SCR GENERATOR WINDOWS LAYOUT ((see floor actual layout with dimensions for your design reference)
		PLUG BOARD LAYOUT
		SYSTEM SINGLE LINE DIAGRAM
		CONTROL CABLE INTERCONNECTION DC POWER INTERCONNECTION GEN CONTROL CABLE INTERCONNECTION
		DRILLER CONSOLE LAYOUT MODEL
		*One/Single Line Diagram
		*DC Power Interconnect showing the assignment Switch(Tripping and Drilling Operations)
		*Drillers Control Interface(HMI, Rheostat, Torque Limit, Foot throttlre)(see attached with dimensions for you design reference)
		*******NOTHING FOLLOWS********